

Table of Contents

Purpose.....	3.....
Definitions.....	3.....
Responsibilities.....	3.....
Hot Work Permitted Locations.....	5.....
Fire Prevention Precautions.....	5.....
PersonalProtective Equipment.....	6.....
Training.....	6.....
Hot Work Permit Procedure.....	6.....
Hot Work Permit Valid.....	7.....
APPENDIX A-Hot Work Checklist.....	8.....

- x Issuing hot work permits for work areas.
- x Reviewing hazards and incidents associated with

APPENDIX A Hot Work Checklist

Fire Protection

1. Sprinklers and smoke detectors have been covered/disabled.
2. A trained person not directly involved with the work will provide a continuous fire watch during the period of hot work and for at least one hour after it ceases in the work area and those adjoining areas to which sparks and heat may spread.
3. At least two suitable extinguishers are immediately available. Both the personnel undertaking the work and providing the fire watch are trained in their use.
4. Personnel involved with the work and providing the fire watch are familiar with the means of escape and method of initiating an alarm/calling the Fire Department (911 or
9. Protection (metal shields or fire retardant tarps) has been provided for:
 - x Walls, partitions, and ceilings of combustible construction or surface finish
 - x All holes and other openings in walls, partitions, and ceilings through which sparks could pass.
10. Combustible materials have been moved away from the far side of walls or partitions where heat could be conducted, especially where these incorporate metal.